



LEGEND:

- ① - 2" -90° BEND
- ② - 2" TEE
- ③ - STEEL COUPLING
- ④ - 2" VALVE
- ⑤ - 2" STRAINER
- ⑥ - 2" TURBO WATER METER (SEE SPECS.)
- ⑦ - 2" PRESSURE REDUCING VALVE (SEE SPECS.)
- ⑧ - 3/4" ALL THREADED ROOS-BOLTED THRU WALL

NOT TO SCALE

4" WATER METER
BY-PASS
VAULT PLAN VIEW

4.17A

DATE	BY	DESCRIPTION
1/30/04	CKC	CREATED
5/28/22	BGM	CHANGE FONT, TITLE BLOCK, NUMBER
1/05/26	BGM	SPLIT INTO TWO DETAILS