



NOTES:

1. THE THRUST BLOCKING SHALL NOT COVER THE HYDRANT DRAIN HOLE OR WEEP HOLE.
2. FIRE HYDRANT COLOR TO BE RED.
3. HYDRANT DRAINS SHALL NOT BE CONNECTED WITHIN 10' OF SYSTEM.
4. HYDRANT TO BE PLACED WITH PUMPER NOZZLE FACING THE STREET UNLESS OTHERWISE NOTED.

NOT TO SCALE

FIRE HYDRANT  
DETAIL

4.01

9/29/05	CKC	ADDED COLOR CODING
5/28/22	BGM	CHANGE FONT, TITLE BLOCK
5/28/24	BGM	ADD STORZ CONNECTION
DATE	BY	DESCRIPTION