



NOTES:

1. SUMP LOCATION MAY VARY TO ACCOMMODATE POSITIVE OUTFALL DIRECTION.
2. ALL CONNECTIONS IN VAULT TO BE FLANGED. PIPING TO BE DUCTILE IRON.
3. COAT ALL ALUMINUM SURFACES IN CONTACT WITH CONCRETE W/16 MILS "SAFE-TAR" EPOXY CEMENT BY SOUTHERN COATINGS.
4. FOR LEGEND SEE DETAIL 4.16A

NOT TO SCALE

20 LF - 4" PERF. PIPE ENCASED IN 6" MIN. WASHED NO. 57 STONE (ALL SLOPES). DRAIN TO POSITIVE OUTFALL IF WITHIN 20' OF VAULT.

2" WATER METER
BY-PASS
VAULT SECTION A-A

4.16B

DATE	BY	DESCRIPTION
1/30/04	CKC	CREATED
5/28/22	BGM	CHANGE FONT, TITLE BLOCK, NUMBER
1/05/26	BGM	SPLIT INTO TWO DETAILS