



NOTES:

1. SUMP LOCATION MAY VARY TO ACCOMMODATE POSITIVE OUTFALL DIRECTION.
2. ALL CONNECTIONS IN VAULT TO BE FLANGED. PIPING TO BE DUCTILE IRON.
3. COAT ALL ALUMINUM SURFACES IN CONTACT WITH CONCRETE W/16 MILS "SAFE-TAR" EPOXY CEMENT BY SOUTHERN COATINGS.
4. FOR LEGEND SEE DETAIL 4.17A

20 LF - 4" PERF. PIPE ENCASED IN 6" MIN. WASHED NO. 57 STONE (ALL SLOPES). DRAIN TO POSITIVE OUTFALL IF WITHIN 20' OF VAULT.

NOT TO SCALE

4" WATER METER BY-PASS VAULT SECTION A-A

4.17B

1/30/04	CKC	CREATED
5/28/22	BGM	CHANGE FONT, TITLE BLOCK, NUMBER
1/05/26	BGM	SPLIT INTO TWO DETAILS
DATE	BY	DESCRIPTION